FUEL FACILITY CHECKS - DAILY SUMPS	STATION:	FACILITY:	MONTH:	YEAR:

STORAGE TANK SUMP (RECORD RATING OF FIRST SAMPLE TAKEN, AFTER LINE DISPLACEMENT)

RECORD SUMP SAMPLE RATING	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31

FILTER SUMP (RECORD RATING OF FIRST SAMPLE TAKEN, AFTER LINE DISPLACEMENT)

RECORD SUMP SAMPLE RATING	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31

PRODUCT RECLAIM TANK SUMP (RECORD RATING OF FIRST SAMPLE TAKEN, AFTER LINE DISPLACEMENT)

RECORD SUMP SAMPLE RATING	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31

RELAXATION CHAMBERS (RECORD RATING OF FIRST SAMPLE TAKEN, AFTER LINE DISPLACEMENT)

RECORD SUMP SAMPLE RATING	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31

BULK AIR ELIMINATORS (RECORD RATING OF FIRST SAMPLE TAKEN, AFTER LINE DISPLACEMENT)

RECORD SUMP SAMPLE RATING	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
IDENTIFICATION OF PERSON PERFORMING TASKS OR PERSON ACCEPTING RESPONSIBILITY THAT TASKS WERE PERFORMED																															

RATING OF SUMP SAMPLES:

SOLIDS: 1 = CLEAN, 2 = SLIGHT, 3 = PARTICULATE, 4 = DIRTY

WATER: A = BRIGHT, B = HAZY, C = CLOUDY, D = WET (FREE WATER), E = SURFACTANTS

RETAIN ON FILE FOR 12 MONTHS